

ist Hersteller und verantwortlich für:

Konformitätserklärung / Declaration of Conformity


Produkt-Typ:	Plug & Play Photovoltaik-Set für Netzparallelbetrieb steckbar mittels Haushaltsstecker in Endstromkreis
Modell:	385 Wp Plug & Play Solar (CN)
Komponenten:	<ul style="list-style-type: none"> • 1x JA Solar JAM60S20-385/MR / 385 Wp / IP-67 / Schutzklasse II • 1x Hoymiles HM-300 mit N/A Schutz und eingebauter RCMU / IP67 Schutzart / Schutzklasse II / Input max. 60VDC, Output max. 230VAC, 50-60Hz, 300VA, 1,30A • 1x Anschlusskabel vorkonfektioniert mit Betteri Buchse IP67, 5m oder 10m / 3x2,5mm² Leitung / AC Seitig CH-Typ 13 Stecker IP 55

Konform nach ESTI-Mitteilung 07/2014 und in Übereinstimmung mit der Verordnung über elektrische Niederspannungserzeugnisse (NEV; SR 734.26) (Stand 06.03.2023).

Dazu angewandte Normen:

JA Solar JAM60S20-385/MR	EN 61215-1:2016, EN 61215-1-1:2016, IEC 61215-2:2016, EN 61215-2:2017, IEC 61730-1:2016, EN IEC 61730-1:2018, EN IEC 61730-1:2018/AC:2018-06, IEC 61730-2:2016, EN IEC 61730-2:2018, EN IEC 61730-2:2018/AC:2018-06
Hoymiles HM-300	VDE-ARN-N 4105: 2018-11, VDE V 0124-100:2019 & EN50549-1:2019, VFR 2019 IEC/EN 62109-1:2010/-2:2011, IEC/EN 61000-6-1:2019;EN 61000-6-2:200; EN 61000-6-3:2007+A1:2011; EN 61000-6-4:2019; EN 61000-3-2:2019; EN 61000-3-3:2013+A1:2019, IEC/EN 62311:2008 NEMA (IP67) Gehäuse; 6000 V Stromstossschutz
Hoymiles Anschlusskabel vorkonfektioniert in 5m oder 10m ausführung	Betteri Buchse Wechselrichterseite, Schutzart IEC EN 60529 IP67 Anschlusskabel 5m oder 10m H07RN-F, EN 50525-2-21: 2011 Stecker CH Typ 13: IEC 60884-1 (Ed 4.0): 2022 / SN 441011-1: 2019 +Corr2019 / SN 441011-2-1:2021, IP55
ROHS	Gesamtes Set konform gemäss IEC EN 63000: 2018

Michael Sebel, Geschäftsführung
erneuer.bar services GmbH



Technische Daten zu Hoymiles HM-300

Modell	HM-300	HM-350	HM-400
Eingabedaten (DC)			
Leistung des gewöhnlich verbrauchten Moduls(W)	240~380	280~440	320~500
Modulkompatibilität	PV-Module mit 60 Zellen oder 72 Zellen		
Spitzenleistung MPPT des Spannungsbereichs (V)	29~48	33-48	34~48
Anlaufspannung (V)	22	22	22
Betriebsspannungsbereich (V)	16~60	16-60	16~60
Maximale Eingangsspannung (V)	60	60	60
Maximaler Eingangsstrom (A)	11.5	11.5	12.5
Ausgangsdaten (AC)			
Spitzenausgangsleistung (VA)	300	350	400
Nennausgangsstrom (A)	1.36 / 1.30 / 1.25	1.59 / 1.52 / 1.46	1.82 / 1.74 / 1.67
Nennausgangsspannung (V)	220 / 230 / 240	220 / 230 / 240	220 / 230 / 240
Bereich der Nennausgangsspannung (V)	180-275 ¹	180-275 ¹	180-275 ¹
Nennfrequenz/-bereich (Hz)	50/45-55 ¹ oder 60/55-65 ¹	50/45-55 ¹ oder 60/55-65 ¹	50/45-55 ¹ oder 60/55-65 ¹
Leistungsfaktor (einstellbar)	>0,99 standardmäßig 0,8 führend.....0,8 verzögert	>0,99 standardmäßig 0,8 führend.....0,8 verzögert	>0,99 standardmäßig 0,8 führend.....0,8 verzögert
Gesamte harmonische Verzerrung	<3%	<3%	<3%
Maximale Einheiten pro Abweig ²	16 / 16 / 16	14 / 14 / 14	12 / 12 / 12
Effizienz			
CEC-Spitzenwirkungsgrad	96.70%	96.70%	96.70%
CEC-gewichteter Wirkungsgrad	96.50%	96.50%	96.50%
Nominaler MPPT-Wirkungsgrad	99.80%	99.80%	99.80%
Nächtlicher Stromverbrauch (mW)	<50	<50	<50
Mechanische Daten			
Umgebungstemperaturbereich (°C)	-40~+65		
Abmessungen (B×H×T mm)	182 x 164 x 29.5		
Gewicht (kg)	1.98		
Gehäuseeinstufung	Außenbereich-NEMA(IP67)		
Lüftung	Natürliche Umluft – keine Lüfter		
Merkmale			
Kommunikation	2.4 GHz Proprietäre RF (Nordisch)		
Überwachung	Hoymiles-Überwachungssystem		
Garantie	Bis zu 25 Jahre		
Einhaltung	VDE-R-N 410S: 2018, EN 50549-1: 2019, VFR 2019, IEC/EN 62109-1/-2, IEC/EN 61000-6-1/-2/-3/-4, IEC/EN 61000-3-2/-3		

Konformitätserklärung zu JA Solar JAM60S20-385/MR

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT



CERTIFICATE

No. Z2 072092 0295 Rev. 45

Holder of Certificate: Shanghai JA Solar Technology Co., Ltd.
No. 118, Lane 3111
West Huancheng Road
Fengxian District
201401 Shanghai
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:




Product: Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704061604115-60

Valid until: 2027-01-18

Date, 2022-01-20


(Zhulin Zhang)



Product Service

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT

CERTIFICATE

No. Z2 072092 0295 Rev. 45

Model(s):

1500 V DC Maximum System voltage, Fire Safety Class A or C Modules:
 JAM72D00-xxx/BP/1500V, JAM72D00-xxx/BP, xxx= 330 to 385 in steps of 5;
 JAM60D00-xxx/BP/1500V, JAM60D00-xxx/BP, xxx= 275 to 320 in steps of 5;
 JAM60D00-xxx/PR/1500V, JAM60D00-xxx/PR, xxx= 285 to 320 in steps of 5;
 JAM72D00-xxx/PR/1500V, JAM72D00-xxx/PR, xxx= 340 to 385 in steps of 5;
 JAM60D00-xxx/MB/1500V, JAM60D00-xxx/MB, xxx= 310 to 315 in steps of 5;
 JAM72D00-xxx/MB/1500V, JAM72D00-xxx/MB, xxx= 370 to 380 in steps of 5;
 JAM72D09-xxx/BP/1500V, JAM72D09-xxx/BP, xxx= 360 to 400 in steps of 5;
 JAM60D09-xxx/BP/1500V, JAM60D09-xxx/BP, xxx= 300 to 340 in steps of 5;
 JAM72D10-xxx/MB/1500V, JAM72D10-xxx/MB, xxx= 385 to 430 in steps of 5;
 JAM60D10-xxx/MB/1500V, JAM60D10-xxx/MB, xxx= 320 to 355 in steps of 5;
 JAM72D10-xxx/BP/1500V, JAM72D10-xxx/BP, xxx= 385 to 415 in steps of 5;
 JAM60D10-xxx/BP/1500V, JAM60D10-xxx/BP, xxx= 320 to 345 in steps of 5;
 JAM66D10-xxx/MB/1500V, JAM66D10-xxx/MB, xxx= 360 to 380 in steps of 5;
 JAM78D10-xxx/MB/1500V, JAM78D10-xxx/MB, xxx= 435 to 455 in steps of 5;
 JAM72D20-xxx/MB/1500V, JAM72D20-xxx/MB, xxx= 430 to 465 in steps of 5;
 JAM60D20-xxx/MB/1500V, JAM60D20-xxx/MB, xxx= 355 to 385 in steps of 5;
 JAM72D10-xxx/TB/1500V, JAM72D10-xxx/TB, xxx= 400 to 420 in steps of 5;
 JAM60D10-xxx/TB/1500V, JAM60D10-xxx/TB, xxx= 335 to 350 in steps of 5;
 JAM78D30-xxx/MB/1500V, JAM78D30-xxx/MB, xxx= 580 to 605 in steps of 5;
 JAM72D30-xxx/MB/1500V, JAM72D30-xxx/MB, xxx= 505 to 555 in steps of 5;
 JAM72D30-xxx/MB/F/1500V, JAM72D30-xxx/MB/F,
 xxx= 505 to 555 in steps of 5;
 JAM66D30-xxx/MB/1500V, JAM66D30-xxx/MB, xxx= 465 to 505 in steps of 5;
 JAM66D30-xxx/MB/F/1500V, JAM66D30-xxx/MB/F,
 xxx= 465 to 505 in steps of 5;
 JAM60D30-xxx/MB/1500V, JAM60D30-xxx/MB, xxx=435 to 460 in steps of 5;
 JAM54D30-xxx/MB/1500V, JAM54D30-xxx/MB, xxx= 390 to 415 in steps of 5;
 JAM50D40-xxx/MB/1500V, JAM50D40-xxx/MB, xxx= 485 to 500 in steps of 5;
 JAM78D30-xxx/GB/1500V, JAM78D30-xxx/GB, xxx= 585 to 595 in steps of 5;
 JAM72D30-xxx/GB/1500V, JAM72D30-xxx/GB, xxx= 540 to 550 in steps of 5;
 JAM66D30-xxx/GB/1500V, JAM66D30-xxx/GB, xxx= 495 to 500 in steps of 5;
 JAM60D30-xxx/GB/1500V, JAM60D30-xxx/GB, xxx= 450 to 455 in steps of 5;
 JAM54D30-xxx/GB/1500V, JAM54D30-xxx/GB, xxx= 405 to 410 in steps of 5;
 JAM72D30-xxx/HB/1500V, JAM72D30-xxx/HB, xxx= 530 to 560 in steps of 5;
 JAM78D30-xxx/TB/1500V, JAM78D30-xxx/TB, xxx= 580 to 610 in steps of 5;
 JAM72D30-xxx/TB/1500V, JAM72D30-xxx/TB, xxx= 540 to 560 in steps of 5;
 JAM66D30-xxx/TB/1500V, JAM66D30-xxx/TB, xxx= 500 to 515 in steps of 5;
 JAM60D30-xxx/TB/1500V, JAM60D30-xxx/TB, xxx= 455 to 470 in steps of 5;
 JAM54D30-xxx/TB/1500V, JAM54D30-xxx/TB, xxx= 405 to 420 in steps of 5;

1000 V DC Maximum System voltage, Fire Safety Class C Modules:
 JAM6(K)-72-xxx/PR, xxx= 345 to 370 in steps of 5;
 JAM6(K)-60-xxx/PR, xxx= 285 to 310 in steps of 5;
 JAM6(K)-72-xxx/4BB, xxx= 320 to 345 in steps of 5;
 JAM6(K)-60-xxx/4BB, xxx= 265 to 285 in steps of 5;
 JAM72S01-xxx/SC/1000V, xxx= 320 to 365 in steps of 5;
 JAM60S01-xxx/SC/1000V, xxx= 265 to 305 in steps of 5;
 JAM72S01-xxx/PR/1000V, xxx= 345 to 390 in steps of 5;
 JAM60S01-xxx/PR/1000V, xxx= 285 to 325 in steps of 5;
 JAM72S01-xxx/MR/1000V, xxx= 365 to 385 in steps of 5;
 JAM60S01-xxx/MR/1000V, xxx= 305 to 320 in steps of 5;
 JAM72S03-xxx/PR/1000V, xxx= 360 to 395 in steps of 5;
 JAM60S03-xxx/PR/1000V, xxx= 300 to 330 in steps of 5;
 JAM72S09-xxx/PR/1000V, xxx= 370 to 405 in steps of 5;
 JAM60S09-xxx/PR/1000V, xxx= 310 to 335 in steps of 5;
 JAM72S10-xxx/PR/1000V, xxx= 380 to 410 in steps of 5;
 JAM60S10-xxx/PR/1000V, xxx= 315 to 345 in steps of 5;
 JAM72S10-xxx/MR/1000V, xxx= 390 to 430 in steps of 5;
 JAM60S10-xxx/MR/1000V, xxx= 325 to 355 in steps of 5;
 JAM60S10-xxx/MR-L/1000V, xxx= 325 to 355 in steps of 5;
 JAM78S10-xxx/MR/1000V, xxx= 435 to 465 in steps of 5;
 JAM66S10-xxx/MR/1000V, xxx= 345 to 390 in steps of 5;
 JAM72S09-xxx/BP/1000V, xxx= 375 to 385 in steps of 5;
 JAM60S09-xxx/BP/1000V, xxx= 315 to 320 in steps of 5;
 JAM72S10-xxx/BP/1000V, xxx= 385 to 400 in steps of 5;
 JAM60S10-xxx/BP/1000V, xxx= 320 to 330 in steps of 5;
 JAM72S02-xxx/PR/1000V, xxx= 345 to 390 in steps of 5;
 JAM60S02-xxx/PR/1000V, xxx= 285 to 325 in steps of 5;
 JAM72S02-xxx/SC/1000V, xxx= 320 to 365 in steps of 5;

Page 2 of 6

TUV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

TUV®



Product Service

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT

CERTIFICATE

No. Z2 072092 0295 Rev. 45

JAM60S02-xxx/SC/1000V, xxx= 265 to 305 in steps of 5;
 JAM72S02-xxx/MR/1000V, xxx= 365 to 385 in steps of 5;
 JAM60S02-xxx/MR/1000V, xxx= 305 to 320 in steps of 5;
 JAM72S08-xxx/PR/1000V, xxx= 360 to 395 in steps of 5;
 JAM60S08-xxx/PR/1000V, xxx= 300 to 330 in steps of 5;
 JAM72S12-xxx/PR/1000V, xxx= 365 to 385 in steps of 5;
 JAM60S12-xxx/PR/1000V, xxx= 305 to 330 in steps of 5;
 JAM72S17-xxx/PR/1000V, xxx= 380 to 390 in steps of 5;
 JAM60S17-xxx/PR/1000V, xxx= 315 to 325 in steps of 5;
 JAM72S17-xxx/MR/1000V, xxx= 390 to 430 in steps of 5;
 JAM60S17-xxx/MR/1000V, xxx= 315 to 355 in steps of 5;
 JAM72S10-xxx/MB/1000V, xxx= 395 to 415 in steps of 5;
 JAM60S10-xxx/MB/1000V, xxx= 330 to 345 in steps of 5;
 JAM72S20-xxx/MR/1000V, xxx= 430 to 470 in steps of 5;
 JAM60S20-xxx/MR/1000V, xxx= 355 to 390 in steps of 5;
 JAM78S30-xxx/MR/1000V, xxx= 580 to 605 in steps of 5;
 JAM72S30-xxx/MR/1000V, xxx= 510 to 555 in steps of 5;
 JAM66S30-xxx/MR/1000V, xxx= 470 to 505 in steps of 5;
 JAM60S30-xxx/MR/1000V, xxx= 435 to 460 in steps of 5;
 JAM54S30-xxx/MR/1000V, xxx= 390 to 415 in steps of 5;
 JAM60S21-xxx/MR/1000V, xxx= 355 to 390 in steps of 5;
 JAM50S40-xxx/MR/1000V, xxx= 490 to 500 in steps of 5;
 JAM72S20-xxx/MB/1000V, xxx= 450 to 465 in steps of 5;
 JAM60S20-xxx/MB/1000V, xxx= 375 to 390 in steps of 5;
 JAM72S31-xxx/MR/1000V, xxx= 510 to 545 in steps of 5;
 JAM66S31-xxx/MR/1000V, xxx= 470 to 500 in steps of 5;
 JAM60S31-xxx/MR/1000V, xxx= 425 to 450 in steps of 5;
 JAM54S31-xxx/MR/1000V, xxx= 385 to 405 in steps of 5;
 JAM76S11-xxx/PR(B)/1000V, xxx= 395 to 415 in steps of 5;
 JAM78S30-xxx/GR/1000V, xxx= 575 to 600 in steps of 5;
 JAM72S30-xxx/GR/1000V, xxx= 535 to 555 in steps of 5;
 JAM66S30-xxx/GR/1000V, xxx= 500 to 505 in steps of 5;
 JAM60S30-xxx/GR/1000V, xxx= 445 to 460 in steps of 5;
 JAM54S30-xxx/GR/1000V, xxx= 400 to 415 in steps of 5;
 JAM78S31-xxx/GR/1000V, xxx= 570 to 590 in steps of 5;
 JAM72S31-xxx/GR/1000V, xxx= 525 to 545 in steps of 5;
 JAM66S31-xxx/GR/1000V, xxx= 480 to 500 in steps of 5;
 JAM60S31-xxx/GR/1000V, xxx= 430 to 450 in steps of 5;
 JAM54S31-xxx/GR/1000V, xxx= 395 to 405 in steps of 5;
 JAM72S17-xxx/GR/1000V, xxx= 385 to 400 in steps of 5;

1000 V DC or 1500 V DC Maximum System voltage,
 Fire Safety Class C Modules:

JAM72S01-xxx/SC, xxx= 320 to 365 in steps of 5;
 JAM60S01-xxx/SC, xxx= 265 to 305 in steps of 5;
 JAM60S01-xxx/PR, xxx= 285 to 325 in steps of 5;
 JAM72S01-xxx/MR, xxx= 365 to 385 in steps of 5;
 JAM60S01-xxx/MR, xxx= 305 to 320 in steps of 5;
 JAM72S03-xxx/PR, xxx= 360 to 395 in steps of 5;
 JAM60S03-xxx/PR, xxx= 300 to 330 in steps of 5;
 JAM72S09-xxx/PR, xxx= 370 to 405 in steps of 5;
 JAM60S09-xxx/PR, xxx= 310 to 335 in steps of 5;
 JAM72S10-xxx/PR, xxx= 380 to 410 in steps of 5;
 JAM60S10-xxx/PR, xxx= 315 to 345 in steps of 5;
 JAM72S10-xxx/MR, xxx= 390 to 430 in steps of 5;
 JAM60S10-xxx/MR, xxx= 325 to 355 in steps of 5;
 JAM60S10-xxx/MR-L, xxx= 325 to 355 in steps of 5;
 JAM78S10-xxx/MR, xxx= 435 to 465 in steps of 5;
 JAM66S10-xxx/MR, xxx= 345 to 390 in steps of 5;
 JAM72S09-xxx/BP, xxx= 375 to 385 in steps of 5;
 JAM60S09-xxx/BP, xxx= 315 to 320 in steps of 5;
 JAM72S10-xxx/BP, xxx= 385 to 400 in steps of 5;
 JAM60S10-xxx/BP, xxx= 320 to 330 in steps of 5;
 JAM72S02-xxx/PR, xxx= 345 to 390 in steps of 5;
 JAM60S02-xxx/PR, xxx= 285 to 325 in steps of 5;
 JAM72S02-xxx/SC, xxx= 320 to 365 in steps of 5;
 JAM60S02-xxx/SC, xxx= 265 to 305 in steps of 5;
 JAM72S02-xxx/MR, xxx= 365 to 385 in steps of 5;
 JAM60S02-xxx/MR, xxx= 305 to 320 in steps of 5;
 JAM72S08-xxx/PR, xxx= 360 to 395 in steps of 5;



Product Service

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT

CERTIFICATE

No. Z2 072092 0295 Rev. 45

JAM60S08-xxx/PR, xxx= 300 to 330 in steps of 5;
 JAM72S12-xxx/PR, xxx= 365 to 385 in steps of 5;
 JAM60S12-xxx/PR, xxx= 305 to 330 in steps of 5;
 JAM72S17-xxx/PR, xxx= 380 to 390 in steps of 5;
 JAM60S17-xxx/PR, xxx= 315 to 325 in steps of 5;
 JAM72S17-xxx/MR, xxx= 390 to 430 in steps of 5;
 JAM60S17-xxx/MR, xxx= 315 to 355 in steps of 5;
 JAM72S10-xxx/MB, xxx= 395 to 415 in steps of 5;
 JAM60S10-xxx/MB, xxx= 330 to 345 in steps of 5;
 JAM72S20-xxx/MR, xxx= 430 to 470 in steps of 5;
 JAM60S20-xxx/MR, xxx= 355 to 390 in steps of 5;
 JAM78S10-xxx/MR-J, xxx= 435 to 465 in steps of 5;
 JAM78S30-xxx/MR, xxx= 580 to 605 in steps of 5;
 JAM72S30-xxx/MR, xxx= 510 to 555 in steps of 5;
 JAM66S30-xxx/MR, xxx= 470 to 505 in steps of 5;
 JAM60S30-xxx/MR, xxx= 435 to 460 in steps of 5;
 JAM54S30-xxx/MR, xxx= 390 to 415 in steps of 5;
 JAM60S21-xxx/MR, xxx= 355 to 390 in steps of 5;
 JAM50S40-xxx/MR, xxx= 490 to 500 in steps of 5;
 JAM72S20-xxx/MB, xxx= 450 to 465 in steps of 5;
 JAM60S20-xxx/MB, xxx= 375 to 390 in steps of 5;
 JAM68S11-xxx/PR, xxx= 355 to 365 in steps of 5;
 JAM68S11-xxx/PR(B), xxx= 345 to 365 in steps of 5;
 JAM72S31-xxx/MR, xxx= 510 to 545 in steps of 5;
 JAM66S31-xxx/MR, xxx= 470 to 500 in steps of 5;
 JAM60S31-xxx/MR, xxx= 425 to 450 in steps of 5;
 JAM54S31-xxx/MR, xxx= 385 to 405 in steps of 5;
 JAM76S11-xxx/PR(B), xxx= 395 to 415 in steps of 5;
 JAM78S30-xxx/GR, xxx= 575 to 600 in steps of 5;
 JAM72S30-xxx/GR, xxx= 535 to 555 in steps of 5;
 JAM66S30-xxx/GR, xxx= 500 to 505 in steps of 5;
 JAM60S30-xxx/GR, xxx= 445 to 460 in steps of 5;
 JAM54S30-xxx/GR, xxx= 400 to 415 in steps of 5;
 JAM78S31-xxx/GR, xxx= 570 to 590 in steps of 5;
 JAM72S31-xxx/GR, xxx= 525 to 545 in steps of 5;
 JAM66S31-xxx/GR, xxx= 480 to 500 in steps of 5;
 JAM60S31-xxx/GR, xxx= 435 to 450 in steps of 5;
 JAM54S31-xxx/GR, xxx= 395 to 405 in steps of 5;
 JAM72S17-xxx/GR, xxx= 385 to 400 in steps of 5;

1500 V DC Maximum System voltage, Fire Safety Class C Modules:

JAM6(K)-72-xxx/PR/1500V, xxx= 345 to 370 in steps of 5;
 JAM6(K)-60-xxx/PR/1500V, xxx= 285 to 310 in steps of 5;
 JAM6(K)-72-xxx/4BB/1500V, xxx= 320 to 345 in steps of 5;
 JAM6(K)-60-xxx/4BB/1500V, xxx= 265 to 285 in steps of 5;
 JAM72S01-xxx/SC/1500V, xxx= 320 to 365 in steps of 5;
 JAM60S01-xxx/SC/1500V, xxx= 265 to 305 in steps of 5;
 JAM72S01-xxx/PR, xxx= 345 to 390 in steps of 5;
 JAM60S01-xxx/PR/1500V, xxx= 285 to 325 in steps of 5;
 JAM72S01-xxx/MR/1500V, xxx= 365 to 385 in steps of 5;
 JAM60S01-xxx/MR/1500V, xxx= 305 to 320 in steps of 5;
 JAM72S03-xxx/PR/1500V, xxx= 360 to 395 in steps of 5;
 JAM60S03-xxx/PR/1500V, xxx= 300 to 330 in steps of 5;
 JAM72S09-xxx/PR/1500V, xxx= 370 to 405 in steps of 5;
 JAM60S09-xxx/PR/1500V, xxx= 310 to 335 in steps of 5;
 JAM72S10-xxx/PR/1500V, xxx= 380 to 410 in steps of 5;
 JAM60S10-xxx/PR/1500V, xxx= 315 to 345 in steps of 5;
 JAM72S10-xxx/MR/1500V, xxx= 390 to 430 in steps of 5;
 JAM60S10-xxx/MR/1500V, xxx= 325 to 355 in steps of 5;
 JAM60S10-xxx/MR-L/1500V, xxx= 325 to 355 in steps of 5;
 JAM78S10-xxx/MR/1500V, xxx= 435 to 465 in steps of 5;
 JAM66S10-xxx/MR/1500V, xxx= 345 to 390 in steps of 5;
 JAM72S09-xxx/BP/1500V, xxx= 375 to 385 in steps of 5;
 JAM60S09-xxx/BP/1500V, xxx= 315 to 320 in steps of 5;
 JAM72S10-xxx/BP/1500V, xxx= 385 to 400 in steps of 5;
 JAM60S10-xxx/BP/1500V, xxx= 320 to 330 in steps of 5;
 JAM72S02-xxx/PR/1500V, xxx= 345 to 390 in steps of 5;
 JAM60S02-xxx/PR/1500V, xxx= 285 to 325 in steps of 5;
 JAM72S02-xxx/SC/1500V, xxx= 320 to 365 in steps of 5;
 JAM60S02-xxx/SC/1500V, xxx= 265 to 305 in steps of 5;

Page 4 of 6

TUV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

TUV®



Product Service

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT

CERTIFICATE

No. Z2 072092 0295 Rev. 45

JAM72S02-xxx/MR/1500V, xxx= 365 to 385 in steps of 5;
 JAM60S02-xxx/MR/1500V, xxx= 305 to 320 in steps of 5;
 JAM72S08-xxx/PR/1500V, xxx= 360 to 395 in steps of 5;
 JAM60S08-xxx/PR/1500V, xxx= 300 to 330 in steps of 5;
 JAM72S12-xxx/PR/1500V, xxx= 365 to 385 in steps of 5;
 JAM60S12-xxx/PR/1500V, xxx= 305 to 330 in steps of 5;
 JAM72S17-xxx/PR/1500V, xxx= 380 to 390 in steps of 5;
 JAM60S17-xxx/PR/1500V, xxx= 315 to 325 in steps of 5;
 JAM72S17-xxx/MR/1500V, xxx= 390 to 430 in steps of 5;
 JAM60S17-xxx/MR/1500V, xxx= 315 to 355 in steps of 5;
 JAM72S10-xxx/MB/1500V, xxx= 395 to 415 in steps of 5;
 JAM60S10-xxx/MB/1500V, xxx= 330 to 345 in steps of 5;
 JAM72S20-xxx/MR/1500V, xxx= 430 to 470 in steps of 5;
 JAM60S20-xxx/MR/1500V, xxx= 355 to 390 in steps of 5;
 JAM78S30-xxx/MR/1500V, xxx= 580 to 605 in steps of 5;
 JAM72S30-xxx/MR/1500V, xxx= 510 to 555 in steps of 5;
 JAM66S30-xxx/MR/1500V, xxx= 470 to 505 in steps of 5;
 JAM60S30-xxx/MR/1500V, xxx= 435 to 460 in steps of 5;
 JAM54S30-xxx/MR/1500V, xxx= 390 to 415 in steps of 5;
 JAM60S21-xxx/MR/1500V, xxx= 355 to 390 in steps of 5;
 JAM50S40-xxx/MR/1500V, xxx= 490 to 500 in steps of 5;
 JAM72S20-xxx/MB/1500V, xxx= 450 to 465 in steps of 5;
 JAM60S20-xxx/MB/1500V, xxx= 375 to 390 in steps of 5;
 JAM72S31-xxx/MR/1500V, xxx= 510 to 545 in steps of 5;
 JAM66S31-xxx/MR/1500V, xxx= 470 to 500 in steps of 5;
 JAM60S31-xxx/MR/1500V, xxx= 425 to 450 in steps of 5;
 JAM54S31-xxx/MR/1500V, xxx= 385 to 405 in steps of 5;
 JAM76S11-xxx/PR(B)/1500V, xxx= 395 to 415 in steps of 5;
 JAM78S30-xxx/GR/1500V, xxx= 575 to 600 in steps of 5;
 JAM72S30-xxx/GR/1500V, xxx= 535 to 555 in steps of 5;
 JAM66S30-xxx/GR/1500V, xxx= 500 to 505 in steps of 5;
 JAM60S30-xxx/GR/1500V, xxx= 445 to 460 in steps of 5;
 JAM54S30-xxx/GR/1500V, xxx= 400 to 415 in steps of 5;
 JAM78S31-xxx/GR/1500V, xxx= 570 to 590 in steps of 5;
 JAM72S31-xxx/GR/1500V, xxx= 525 to 545 in steps of 5;
 JAM66S31-xxx/GR/1500V, xxx= 480 to 500 in steps of 5;
 JAM60S31-xxx/GR/1500V, xxx= 435 to 450 in steps of 5;
 JAM54S31-xxx/GR/1500V, xxx= 395 to 405 in steps of 5;
 JAM72S17-xxx/GR/1500V, xxx= 385 to 400 in steps of 5;
 xxx is standing for rated output power at STC

Parameters:

Construction:	Framed or Frameless, with Junction box, Cable and Connectors.
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute No. 10 West Kaifa Road, Yangzhou 225009 Jiangsu, P. R. China
Safety Class:	Class II
Maximum System Voltage:	1500 V DC or 1000 V DC
Fire Safety Class:	Class C or Class A according to UL790.
Production Facility(ies):	079395, 105674, 107160, 095903, 090968, 096558, 108293, 102852, 108746, 072092, 109998, 112017, 108944, 004170, 112715, 113691, 113943, 114922.



ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT

CERTIFICATE

No. Z2 072092 0295 Rev. 45

**Tested
according to:**

IEC 61215-1:2016
EN 61215-1:2016
IEC 61215-1-1:2016
EN 61215-1-1:2016
IEC 61215-2:2016
EN 61215-2:2017
IEC 61730-1:2016
EN IEC 61730-1:2018
EN IEC 61730-1:2018/AC:2018-06
IEC 61730-2:2016
EN IEC 61730-2:2018
EN IEC 61730-2:2018/AC:2018-06

Konformitätserklärung zu Hoymiles HM-300



Zertifikat für den NA-Schutz

Hersteller / Antragsteller: Hoymiles Converter Technology Co., Ltd.
No. 18 Kangjing Road,
HangZhou, Zhejiang Province
P.R. China

Typ NA-Schutz:	Integrierter NA-Schutz
Zugeordnet zu Erzeugungseinheit Typ:	HM-250, HM-250A, HM-250T, HM-300, HM-300A, HM-300T, HM-350, HM-350A, HM-350T, HM-400, HM-400A, HM-400T, HM-450, HM-450A, HM-450T, HM-500, HM-500T, HM-600, HM-600T, HM-700, HM-700T, HM-800, HM-800T

Firmwareversion: ab V01.01.00

Netzanschlussregel: VDE-AR-N 4105:2018-11 – Erzeugungsanlagen am Niederspannungsnetz
Technische Mindestanforderungen für Anschluss und Parallelbetrieb von Erzeugungsanlagen am Niederspannungsnetz

Mitteltende Normen / Richtlinien: DIN VDE V 0124-100 (VDE V 0124-100):2019-09 – Netzintegration von Erzeugungsanlagen – Niederspannung
Prüfanforderungen an Erzeugungseinheiten vorgesehen zum Anschluss und Parallelbetrieb am Niederspannungsnetz

Der oben bezeichnete NA-Schutz wurde nach der Prüfrichtlinie VDE 0124-100 geprüft und zertifiziert. Die in der Netzanschlussregel geforderten elektrischen Eigenschaften werden erfüllt:

- Einstellwerte und die Abschaltzeiten
- Funktionstüchtige Wirkungskette „NA-Schutz-Kuppelschalter“
- Technische Anforderungen der Schalteinrichtung
- Aktive Inselnetzkerknennung
- Einfehlersicherheit

Das Zertifikat beinhaltet folgende Angaben:

- Technische Daten des NA-Schutz und zugehörige EZE Typen
- Einstellwerte der Schutzfunktionen
- Auslösewerte der Schutzfunktionen

Berichtsnummer: BMH-ESH-P200410697-1
BMH-ESH-P200410697-2

Zertifizierungsprogramm: NSOP-0032-DEU-ZE-V01

Zertifikatsnummer: U20-0692

Ausstellungsdatum: 2020-08-26



Zertifizierungsstelle der Bureau Veritas Consumer Products Services Germany GmbH akkreditiert nach DIN EN ISO/IEC 17065

Eine auszugsweise Darstellung des Zertifikats bedarf der schriftlichen Genehmigung der Bureau Veritas Consumer Products Services Germany GmbH



Anhang zum Zertifikat für den NA-Schutz Nr. U20-0692

E.6 und E.7 Anforderungen an den Prüfbericht zum NA-Schutz

Auszug aus dem Prüfbericht für den NA-Schutz
„Bestimmung der elektrischen Eigenschaften“

Nr. BMH-ESH-P200410697-1

Nr. BMH-ESH-P200410697-2

NA-Schutz als integrierter NA-Schutz

Hersteller / Antragsteller:	Hoymiles Converter Technology Co., Ltd. No. 18 Kangjing Road, HangZhou, Zhejiang Province P.R. China
Typ NA-Schutz:	Integrierter NA-Schutz
Zugeordnet zu Erzeugungseinheit Typ:	HM-250, HM-250A, HM-250T, HM-300, HM-300A, HM-300T, HM-350, HM-350A, HM-350T, HM-400, HM-400A, HM-400T, HM-450, HM-450A, HM-450T, HM-500, HM-500T, HM-600, HM-600T, HM-700, HM-700T, HM-800, HM-800T
Firmwareversion:	V01.01.00
Integrierter Kuppelschalter:	Typ Schalteinrichtung 1: HF-Transformator Typ Schalteinrichtung 2: Relais
Messzeitraum:	2020-04-12 - 2020-07-30

Schutzfunktion	Einstellwert	Auslösewert	Abschaltzeit ^a
Spannungsrückgangsschutz U<	184,0 V	183,4 V	3060 ms
Spannungsrückgangsschutz U<<	103,5 V	102,8 V	348ms
Spannungssteigerungsschutz U>	253,0 V	--	580,0 s ^b
Spannungssteigerungsschutz U>>	287,5 V	288,4 V	192,1 ms
Frequenzrückgangsschutz f<	47,50 Hz	47,50 Hz	196,0 ms
Frequenzsteigerungsschutz f>	51,50 Hz	51,50 Hz	198,4 ms

^a davon Eigenzeit des Kuppelschalters 6 ms

^b längste Abschaltung des Spannungssteigerungsschutz als gleitender 10-min-Mittelwert, nach 5.5.7 Schutzeinrichtungen und Schutzeinstellungen aus der VDE 0124-100

Die Abschaltzeit (Summe der Auslösezeit NA-Schutz zzgl. Eigenzeit des Kuppelschalters) darf 200 ms nicht überschreiten.

Die Überprüfung der Gesamtwirkungskette „NA-Schutz – Kuppelschalter“ führte zu einer erfolgreichen Abschaltung.

Der oben genannte NA-Schutz hat mit den zugeordneten Erzeugungseinheiten die Anforderungen zur Inselnetzerkennung mit Hilfe aktiven Verfahrens (Schwingkreistest) erfüllt.

Der oben genannte NA-Schutz erfüllt die Anforderungen zur Synchronisation.



BV LCIE
CHINA
Number

N° 2066AS05BMH35313

ATTESTATION of conformity with European Directives

Product: PV Microinverter (Grid-tied photovoltaic Microinverter)
HM-1500, HM-1200, HM-1000, HM-1500T, HM-1200T, HM-1000T, HM-800T, HM-800, HM-700, HM-700T, HM-600, HM-600T,
Reference HM-500, HM-500T, HM-250, HM-250A, HM-250T, HM-300, HM-300A, HM-300T, HM-350, HM-350A, HM-350T, HM-400, HM-400A, HM-400T, HM-450, HM-450A, HM-450T
Issued to Hoymiles Converter Technology Co., Ltd.
Address No. 18 Kangjing Road, HangZhou, Zhejiang Province
Technical characteristics See Next Page

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 50549-1:2019	BMH-ESH-P200408503-1	20/04/2020
	BMH-ESH-P200408503-2	12/05/2020
	BMH-ESH-P200408503-3	19/05/2020

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), May 28th, 2020.



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
必维欧亚电气技术咨询服务(上海)有限公司
Version 3/2016.02.19

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email: contact@cn.bureauveritas.com



LCIE

BV LCIE
CHINA
Number

N° 2066AS05BMH35313

Model / Type.....:	HM-1500 HM-1500T	HM-1200 HM-1200T	HM-1000 HM-1000T
Range of Peak Power MPPT Voltage.....:	36-48V d.c.	29-48V d.c.	27-48V d.c.
Max. Input voltage [V].....:	60 V d.c.		
Max. Continuous Input current [A].....:	4*11,5A d.c.		4*10,5A d.c.
Nominal Output voltage [V].....:	220/230/240V a.c. 50/60 Hz		
Max. Continuous Output AC current [A].....:	7,5	6	5
Max. Continuous Output power [VA].....:	1500	1200	1000

Model / Type.....:	HM-800 HM-800T	HM-700 HM-700T	HM-600 HM-600T	HM-500 HM-500T
Range of Peak Power MPPT Voltage.....:	34-48V d.c.	33-48V d.c.	29-48V d.c.	27-48V d.c.
Max. Input voltage [V].....:	60 V d.c.			
Max. Continuous Input current [A].....:	2*12,5 A d.c.	2*11,5 A d.c.		2*10,5 A d.c.
Nominal Output voltage [V].....:	220/230/240V a.c. 50/60 Hz			
Max. Continuous Output AC current [A].....:	4,0	3,5	3,0	2,5
Max. Continuous Output power [VA].....:	800	700	600	500

Shanghai (P.R. China),), May 28th, 2020.



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
必维欧亚电气技术咨询服务有限公司
有限公司

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email: contact@cn.bureauveritas.com

Version 3/2016.02.19





EU-Type Examination Certificate

with respect to the presumption of
Compliance of a product with the essential requirements of

RE DIRECTIVE 2014/53/EU

Certificate Number	CS32227
Certificate Holder	Hoymiles Power Electronics Inc.
Address	No. 18 Kangjing Road, Hangzhou, Zhejiang Province, P.R. China
Manufacturer	Hoymiles Power Electronics Inc.
Address	No. 18 Kangjing Road, Hangzhou, Zhejiang Province, P.R. China
Product Type/Description	PV Microinverter
Trade Name	Hoymiles
Model Number	HM-450, HM-450T, HM-450A, HM-400, HM-400T, HM-400A, HM-350, HM-350T, HM-350A, HM-300, HM-300T, HM-300A, HM-250, HM-250T, HM-250A, MI-450, MI-450T, MI-400, MI-400T, MI-350, MI-350T, MI-300, MI-300T, MI-250, MI-250T
Product Identification Element	HM-450, HM-450T, HM-450A, HM-400, HM-400T, HM-400A, HM-350, HM-350T, HM-350A, HM-300, HM-300T, HM-300A, HM-250, HM-250T, HM-250A, MI-450, MI-450T, MI-400, MI-400T, MI-350, MI-350T, MI-300, MI-300T, MI-250, MI-250T

Applied / Complied Harmonized Standards		Complied
RE Directive 2014/53/EU, Article 3(1)(a) ■ Safety	EN 62109-1:2010, EN 62109-2:2011	Y
RE Directive 2014/53/EU, Article 3(1)(a) ■ Health	EN 62311:2008	Y
RE Directive 2014/53/EU, Article 3(1)(b) ■ EMC	EN 301 489-1 V2.2.3, EN 301 489-3 V2.1.1 EN IEC 61000-6-1:2019, EN 61000-6-2:2005, EN 61000-6-3:2007+A1:2011, EN IEC 61000-6-4:2019, EN IEC 61000-3-2:2019, EN 61000-3-3:2013+A1:2019	Y
RE Directive 2014/53/EU, Article 3(2) ■ Radio	EN 300 440 V2.1.1	Y

Authorized By: *Darren Shih*

Darren Shih, Senior Manager

Issue Date: Jan. 12, 2021

Expiry Date: Jan. 11, 2026

PS: This Certificate is issued in accordance with Annex III of the RE Directive 2014/53/EU and is only valid in conjunction with the following Annex I.